

Preliminary Assessment Report

Project 3019451, 10033 29TH AVE NE

Assessment Completed: 1/9/2015

Project Description: Change of use of single family residence to private school use.

Primary Applicant: [Steve Southerland](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Department of Planning and Development (DPD) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with DPD. **Please bring a copy of this report to your intake appointment.**

Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

DPD Drainage Requirements

Arthur Thomas Richardson, (206) 684-3655, art.richardson@seattle.gov

DPD Land Use Requirements

Malli Anderson, (206) 233-3858, Malli.Anderson@Seattle.Gov

DPD Preapplication Site Visit Requirements

Kathleen H Wilson, (206) 233-7932, Kathleen.Wilson@seattle.gov

Seattle City Light Requirements

Benjamin Rushwald, (206) 733-9830

Seattle Department of Transportation Requirements

Yohannes Minas, (206) 733-9044, yohannes.minas@seattle.gov

Seattle Public Utilities Requirements

Steve Resnick, (206) 233-7234, ResnicS@seattle.gov

Other Resources

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [DPD](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

Requirements

DPD Drainage Requirements

The following requirements are based on the current stormwater and side sewer codes.

Existing Public Drainage Infrastructure

Sanitary sewer main location: 29th Ave NE / Private SS north PL

Sanitary sewer main size: 8-inch / 8-inch

Drainage

The drainage point of discharge (SMC 22.805.020) is located at: On site (infiltration).

Water Quality

No requirements

Permanent and Temporary Dewatering

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following:
Onsite (infiltration).

DPD Land Use Code Requirements

Street Requirements

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

29TH AVE NE

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

Land Use

Based on the proposed use and location within a residential, multi-family, or commercial zone, an administrative conditional use permit may be required. See CAMs 211A and 211B for more details.

Other Requirements

Based on the preliminary scope of the project, DPD recommends a presubmittal conference prior to submitting an application. Details for preparing and submitting a presubmittal conference request form can be found at our Web site ([http://www.seattle.gov/dpd/Publications/Forms/Building Permits/default.asp](http://www.seattle.gov/dpd/Publications/Forms/Building_Permits/default.asp)).

Pre-Application Site Visit (PASV) Requirements

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

Note: Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

ECA Mapping Unit and Type

Non-ECA

Existing ROW Conditions

29TH AVE NE

Street conditions:

Asphalt paving

Unimproved

Curb conditions:

No curb adjacent to site

A storm inlet does not appear to be located <350 ft from the site and prior to crossing a public right of way.

Tree Protection

Trees greater than 6 inches in diameter as measured 4.5 ft above ground are present on the site but not shown on the site plan. Show the dripline of

- 1) **all** trees on the site,
- 2) adjacent trees that encroach on the site that are greater than 6 inches in diameter as measured 4.5 ft above ground, and
- 3) **all** trees located in the adjacent ROW.

Include common and scientific names for all trees shown. For more information, see [Director's Rule 16-2008](#) and [Tip 242](#).

Seattle City Light Requirements

Notes to Applicant

For new service, an Application for Electrical Service must be submitted to Seattle City Light. Please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. The Electrical Service Representative should also be contacted to coordinate electrical disconnections prior to demolition and temporary power for construction. Your Electrical Service Representative is: Dave Kylen, 206-615-0607, david.kylen@seattle.gov. Be advised that it is the applicant's responsibility to seek guidance from SCL. Failure to contact SCL at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

SDOT Requirements

Based on the information provided at this time, it appears that no street improvements are **required**. All work in the right-of-way requires a permit. Therefore, if you are planning discretionary improvements you should contact SDOT as soon as possible. Be advised that it is the applicant's responsibility to seek guidance from SDOT Street Use should the scope of the project change, or should the applicant become aware of proposed construction in the ROW. Failure to contact SDOT at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

SPU Requirements

Based on the information provided at this time, it appears that no street improvements are required. Be advised that it is the applicant's responsibility to seek guidance from SPU should the scope of the project change, or should the applicant become aware of proposed construction in the ROW. Failure to contact SPU at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at:

http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos_004542.pdf. For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, Liz.Kain@seattle.gov.

Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or www.seattle.gov/neighborhoods/preservation to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your DPD intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our DPD intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, Michale.Crooks@seattle.gov, or visit the [Licensing and Tax Administration Division website](#).